


**MONROE TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY**
Middlesex County, New Jersey



**Rules and Regulations
for
Proposed Water Systems**

2007 MEMBERS OF THE AUTHORITY

RONALD APPLEBY, Chairman
ALAN BINAGHI, Vice Chairman
GEORGE O'CARROLL, Secretary
MICHAEL KONOWICZ, Treasurer
LEONORE FARBER, Assistant Secretary/Treasurer

MICHAEL A. ROGERS, P.E., P.P, Executive Director
RYAN KRAUSE, P.E. Staff Engineer
WILLIAM C. MORAN, JR. ESQ, Attorney

Revised December 21, 2006

CODED SYSTEMS LLC
120 Main Street • Avon • New Jersey 07717

Monroe Township Municipal Utilities Authority
Rules and Regulations
For
Proposed Water Systems

Introduction

The Monroe Township Municipal Utilities Authority was created by Ordinance of the Township of Monroe adopted on June 5, 1961 pursuant to Municipal Utilities Authorities Law N.J.S.A. 4:14-B-1 et seq.

N.J.S.A. 40:14b-20(12) grants Authorities the right "to make and enforce bylaws or Rules and Regulations for the management and regulation of its business and affairs and for the use, maintenance and operation of the utilities system and any other of its properties, and to amend the same."

These Rules and Regulations are adopted pursuant to that grant of power and are applicable to all properties within the Township of Monroe and outside the Township of Monroe through Agreements with other Municipalities, which properties require domestic, commercial or industrial water use pursuant to statute or to these Rules and Regulations. These Rules and Regulations are consistent with N.J.A.C. 5:21 "Residential Site Improvement Standards". Any questions as to this consistency should be raised prior to approval of plans and specifications in order not to create delays and unsafe conditions in the field.

It is the MTMUA's intent to review applications for constructability and serviceability.

The applicant remains solely responsible for the design and installation of the utilities system and its ability to function as intended.

Revised 2-19-05

Any variations from the Rules & Regulations must be approved by the Authority in writing.

The MTMUA will provide copies of any pertinent as-built data from its files for use in the design process. However, the MTMUA has not verified the accuracy of the as-built data and it is the applicant's responsibility to verify any and all information prior to submitting application for approval.

Pursuant to the State of New Jersey's Department of Environmental Protection Bureau

of Safe Drinking Water (Safe Drinking Water Act Regulations, N.J.A.C.7:10- November 4, 2004), and the New Jersey Department of Environmental Protection Geographic Information System Mapping and Digital Data Standards (July 1, 2002) requirements; the Monroe Township Municipal Utilities Authority requires all permit applications to be accompanied by digital data that conforms to said standard.

All digital geographic information system (GIS) data must be in the North American Horizontal Geodetic Datum of 1983 and the New Jersey State Plane Coordinate System (FIPS zone 2900). Vertical data must be submitted in the North American Datum of 1988 (NAVD 88). A conversion factor to the older National Geodetic Vertical Datum of 1929 (NGVD 29) shall also be furnished.